

No: G-2259/19

Office of the District Fire Officer,  
Fire & Rescue Services, Thrissur  
Dated. 25.04.2019

**NO OBJECTION CERTIFICATE**

The L.P.G Cylinder serial connection arrangement in the Chemistry Laboratory of 'Salsabeel Green School, Kiraloor, in Sy.No: 108/1 , in Kiraloor Village, Velur Grama Panchayath, Thalappilly Taluk, Thrissur District owned by **Sri.P.T.M.Hussain, Manager, Salsabeel Green Scholl. Kiraloor, Thrissur-680 601** was inspected by me on **25.04.2019** in Fire Safety point of view under Petroleum Act & Rules. Adequate first aid fire protection arrangements have been provided in the Chemistry Laboratory of the above said school at the time of my inspection.

The first aid fire fighting equipments provided in the Chemistry Laboratory is considered sufficient to use One No (One Number only) L.P.G. Cylinders in series connection. Therefore this department has No Objection in using one L.P.G cylinder in the Chemistry Laboratory of the school mentioned above.



  
District Fire Officer,  
Fire & Rescue Services,  
Thrissur

**Sri.P.T.M.Hussain,**  
Manager,  
Salsabeel Green Scholl.  
Kiraloor, Thrissur-680 601

  
**PRINCIPAL**  
**SALSABEEL GREEN SCHOOL**  
**KIRALOOR**

  
**MANAGER**  
**SALSABEEL GREEN SCHOOL**  
**KIRALOOR**